


## SAFETY CERTIFICATE

The School Building of Rudra International School Basal Tehsil & Distt. Una (HP) has been inspected by the Junior Engineer concerned Section on dated 25.05.2021 As reported by Assistant Engineer Dera Baba Rudru (Basal) Sub Division vide letter No PW/DBRSD/Build/2021 - 460 dated 05.07.2021, it has been observed that no earth quake resistant Provisions have been adopted for this building and no Structural drawings approved by the Competent Govt. Certified Engineer have been produced at the time of inspection. Moreover no assistance was taken from PWD for constructing the building. This Structure is a non-engineered Structure. Hence the Structural Safety of this building cannot be ensured specifically from earthquake resistance point of view. This department will not be held responsible for any type of loss of life and property etc. if this structure fails under any circumstances.

However as per visual inspection the building has been found safe at present only. No officer / official of this department will attend please in any Hon'ble Court of law in case of any dispute. This certificate is valid for the year 2021-22.

  
Executive Engineer  
Bangana Division  
HP.PWD.Bangana 